

a/77871
CPUB.

CANADA
DEPARTMENT OF ENERGY, MINES AND RESOURCES
CANADA CENTRE FOR MINERAL AND ENERGY TECHNOLOGY
OTTAWA

Energy Research Laboratories
Divisional Report ERL 75/36-CCRL

BOILER ACCEPTANCE TESTS
CENTRAL HEATING PLANT, CFB OTTAWA NORTH
ROCKLIFFE, ONTARIO
JANUARY 14-15, 1975

by
A.C.S. Hayden and R.G. Fohse

March 1975



ERL 75-36 CCRL
ERL 75-036-CCRL.

BOILER ACCEPTANCE TESTS
CENTRAL HEATING PLANT, CFB OTTAWA NORTH
ROCKLIFFE, ONTARIO
JANUARY 14-15, 1975

by

A.C.S. Hayden* and R.G. Fohse**

INTRODUCTION

At the request of G. MacDonald, Utilities Officer, CFB Ottawa-North, Department of National Defence, staff of the Canadian Combustion Research Laboratory conducted performance tests on Boiler Number 2 of the Central Heating Plant of CFB Ottawa North. This boiler had originally been stoker-fired and had been converted to be fired by either No. 4 fuel oil or natural gas. The purpose of the tests was to measure the performance of the new firing systems with respect to contract specifications.

**Research Scientist and **Senior Scientific Officer, Canadian Combustion Research Laboratory, Energy Research Laboratories, Canada Centre for Mineral and Energy Technology, Department of Energy, Mines and Resources, Ottawa.*

DESCRIPTION OF EQUIPMENT

The Central Heating Plant of CFB Ottawa North is equipped with four watertube boilers, numbered 1 to 4. Details of manufacturer and ratings are as follows:

Boiler No. 1:	John Inglis	400 HP
Boiler No. 2:	Foster Wheeler	3100 lbs of steam/hr
Boiler No. 3 and No. 4:	Waterous	3100 lbs of steam/hr

The boiler layout with the numbering system as used for the tests is shown in Figure 1.

Boilers No. 1, 3 and 4 are equipped with Peabody Compower steam atomizing oil burners and natural gas burners. Boiler No. 2, on which these tests were carried out, is equipped with a Todd steam atomizing oil burner, designed to burn fuel oil not heavier than No. 2, and a natural gas burner. Details of the equipment are presented in Appendix A.

Automatic control is provided by a Bailey pneumatic system, with air as the master. For each boiler, steam flow is measured, recorded and integrated by an orifice meter and oil flow is monitored by an integrating displacement meter. A single integrating displacement meter measures the natural gas flow to the Plant.

FUEL ANALYSIS

A sample of the fuel oil was taken by CCRL staff during the tests and submitted for analysis to the Petroleum and Gas Laboratory of the Energy Research Laboratories, Canada Centre for Mineral and Energy Technology (CANMET), Department of Energy, Mines and Resources, Ottawa. The results are shown in Table 1.

The gas supplier, Trans Canada Pipelines Ltd., provided a representative analysis of the natural gas as burned during the tests. This analysis is presented in Table 2.

DESCRIPTION OF TESTS AND RESULTS

Because the contract chiefly involved conversion of the firing equipment to both oil and natural gas firing, the tests were primarily aimed at evaluating boiler performance, but they were also intended to measure overall burner efficiency, to determine the nature of any operational limitations and to establish whether or not the automatic controls were suitably calibrated. For the test, the master-air control was held on manual to obtain the desired load conditions. The fuel flow was allowed to follow on automatic control, in order that the tests would duplicate actual boiler performance conditions. All tests were conducted under stabilized conditions, at loads roughly corresponding to 20%, 66% and 100% of the maximum continuous rating of the boiler. Conditions governing the load and excess air settings, as well as comments on the flame obtained, are summarized in Table 3, for each test.

During the tests, operating data were recorded at fifteen minute intervals, using the Plant instruments, with the following exceptions. Flue gas was monitored continuously by means of infra-red analyzers for CO₂ and CO and a paramagnetic analyzer for oxygen. As a check on the Plant instruments, flue gas temperature was measured with a chromel-alumel, multi-junction averaging thermocouple and a portable potentiometer. The temperatures of the combustion air and the ambient air were measured with mercury thermometers.

The average data recorded for each test, along with the calculated results, are presented in Table 4. Tables 5 to 11 show the heat balances and calculations for tests 1 to 7, respectively, in the ASME Short Form format. Figure 2 presents the efficiency curves for the boiler, for both oil and natural gas firing. On oil firing, the efficiencies average about 82% and on natural gas firing, 78%.

After the constant load tests for each fuel, the boiler was allowed to run from low fire to full load on automatic in a very short period of time (less than ten minutes). On gas firing no problem occurred. However, on oil firing, when the boiler reached full load, the firing rate began to hunt, and the burner cut out. It was found that the governing cam had been cut in such a way that it had a lip at the top end, and once this point was exceeded, the

burner could not return to a lower firing rate. The contractor was made aware of this defect and, before CCRL staff left, reset stops on the controls to prevent this point from being reached. The actual load where this occurred was at a somewhat higher firing rate than the full load test conducted by CCRL, so that the test results apply completely.

DISCUSSION AND CONCLUSIONS

The converted boiler offers consistently good performance on both oil and gas firing. In particular, the performance on oil firing can be considered to be somewhat above average for this type of equipment.

The boiler pressure meter located on the main panel should be recalibrated, as it is consistently reading some 5 psig low. Similarly, the flue gas temperature sensing and recording device should be checked, as it is grossly in error on the low side.

It is recommended that serious consideration be given to the purchase of an oxygen monitoring instrument to measure the oxygen concentration in the flue gas. This, in conjunction with accurate flue gas temperature measurements, can give a rapid determination of boiler efficiency. In particular, paramagnetic oxygen analyzers have been found by CCRL staff to give the best results.

From time to time, checks by Plant staff should be performed on the boiler to ensure that the stops set up by the contractor that firing rate can not increase beyond the smooth region of the burner control cam, where return to lower firing is impossible, as described previously.

In conclusion, it appears that the conversion of these boilers has been carried out in accordance with good industrial practice. The burners themselves are robust in design, provide good control over the flame shape, have an acceptable turn-down ratio, and result in satisfactory boiler efficiencies.




Figure 1. Boiler layout, CFB Ottawa North CHP




Figure 2. Boiler indirect efficiency versus output, Boiler No.2, CFB Ottawa North CHP

TABLE 1

Analysis^{1/} of No. 4 Fuel Oil - CFB Ottawa North

Date:	January 15, 1975
Sample Number:	A004-75; 21-75
Specific Gravity, 60/60°F:	0.898
Viscosity at 122°F, cst:	10.21
Heat of Combustion, Btu/lb:	20,432
Carbon, % by weight:	86.37
Hydrogen, "	12.36
Nitrogen, "	0.11
Sulphur, "	1.14
Vanadium, ppm by weight:	107

^{1/} Analysis performed by the Petroleum and Gas Laboratory, Energy Research Laboratories, Canada Centre for Mineral and Energy Technology, Department of Energy, Mines and Resources, Ottawa.

TABLE 2

Analysis^{1/} of Natural Gas - CFB Ottawa North

Nitrogen, % by weight:	2.21
Carbon Dioxide, "	0.36
Methane, "	93.17
Ethane, "	4.14
Propane, "	0.15
Isobutane, "	0.01
N-butane, "	0.01
Total Sulphur, grains/100 ft ³ :	0.15
Specific Gravity, 60/60°F:	0.588
Heat of Combustion, Btu/1000 ft ³ :	1006

^{1/} *Continuous analysis of natural gas supplied to Ottawa region by TransCanada Pipelines Ltd. over period January 13-17, 1975.*

TABLE 3

Summary of Test Conditions and Operating Limitations - Boiler No. 2

- Test 1: 96% of rating. Natural gas firing. Air on manual, set at 100.
Fuel on automatic. Good, clean, non luminous flame.
- Test 2: 61% of rating. Natural gas firing. Air on manual, set at 55.
Fuel on automatic. Good, clean, non luminous flame with some
yellow traces at 10 o'clock.
- Test 3: 16% of rating. Natural gas firing. Air on manual, set at 0.
Fuel on automatic. Good flame with lazy yellow tips.
- Test 4: 96% of rating. No. 4 oil firing. Air on manual set at 100.
Fuel on automatic. Good, bright flame with no snow. Stack clear.
- Test 5: 61% of rating. No. 4 oil firing. Air on manual, set at 55.
Fuel on automatic. Good, bright flame. Stack clear.
- Test 6: 31% of rating. No. 4 oil firing. Air on manual, set at 20.
Fuel on automatic. Good, bright flame with some lazy tips.
Stack clear.
- Test 7: 18% of rating. No. 4 oil firing. Air on manual, set at 0.
Fuel on automatic. Clean, lazy flame with little snow. Stack
clear.

TABLE 4

Summary of Boiler Acceptance Test Data and Calculations - CFB Ottawa North - Boiler No. 2

Test No.	1	2	3	4	5	6	7
Fuel	Natural gas	Natural gas	Natural gas	No. 4 oil	No. 4 oil	No. 4 oil	No. 4 oil
Rated Capacity, k lb/hr	31	31	31	31	31	31	31
Date	14/1/75	14/1/75	14/1/75	15/1/75	15/1/75	15/1/75	15/1/75
Test Duration, hr	1	1	1	1	1	.5	.25
Steam Pressure, psig							
Drum, blr	132	130	125	126	124	121	121
Drum, panel	126	124	120	120	118	115	115
Header	126	126	125	120	120	120	120
Steam Flow, k lb/hr							
Indicated	29.0	20.6	4.9	30.1	19.7	9.9	5.3
Integrator	29.6	20.6	5.0	30.2	19.4	9.9	5.8
Corrected	29.75	20.70	5.0	29.60	19.01	9.70	5.68
% Rated Capacity	95.7	66.8	16.1	95.5	61.3	31.3	18.3
Air Flow, k lb/hr rel	28.0	20.0	5.1	28.6	20.6	12.9	6.4
Feedwater							
Temp., °F	216	216	217	217	202	204	212
Pressure, psig	165	168	170	160	161	166	166
Air Temperature, °F							
Ambient	74	75	75	72	74	75	75
Combustion	82	81	81	82	81	80	80
Flue Gas Temp., °F							
Panel	392	330	210	400	331	261	220
CCRL	607	517	353	633	535	435	370
F/D Control Setting	100	55	0	100	55	20	0

(cont'd)

TABLE 4 (cont'd)

Summary of Boiler Acceptance Test Data and Calculations - CFB Ottawa North - Boiler No. 2

Test No.	1	2	3	4	5	6	7
Supply Gas							
Temp., °F	35	35	35				
Pressure, psig	37.5	38.0	38.0				
Gas Flow,							
Timed, sec/100 ft ³	36.8	56.8	233				
Integrator, ft ³ /hr	9783	6200	1600				
Gas Burner Press., psig	2.05	1.05	0.20				
Oil Flow							
Temperature				106	106	106	106
Timed, sec/gal				16.73	25.15	49.49	92.2
Integrator, k lb/hr x 10				215.2	143.4	72.8	39.1
Burner Press., psig							
Oil				78	58	34	22
Steam				95	77	51	37
Pressure, in. W.C.							
Windbox	6.1	2.6	0	5.9	2.4	0.4	0
Furnace	0.6	-0.2	-0.5	-0.5	-0.12	-0.5	-0.5
Upstake	-0.45	-0.55	-0.53	-0.39	-0.50	-0.55	-0.55
Flue Gas Analysis							
CO ₂ , % by vol.	10.5	10.4	9.7	13.9	13.3	11.0	11.1
CO, "	.04	.03	.02	-	.03	.03	.03
O ₂ , "	1.93	1.93	3.60	2.51	3.50	6.0	5.8
Excess Air, %	8.85	8.87	18.26	12.61	18.52	36.79	35.07

(cont'd)

TABLE 4 (Cont'd)

Summary of Boiler Acceptance Test Data and Calculations - CFB Ottawa North - Boiler No. 2

Test No.	1	2	3	4	5	6	7
Total Heat Input, k Btu/hr	-	-	-	43970	29290	14874	7989
Total Heat Output, k Btu/hr	30040	20890	5040	29837	19445	9899	5750
Direct Efficiency, %	-	-	-	67.86	66.39	66.55	71.97
Heat Balance (Losses)							
Dry gas loss, %	9.52	7.98	5.35	10.21	8.76	8.20	6.64
Hydrogen loss, %	12.23	11.83	11.11	7.09	6.84	6.59	6.42
CO loss, %	0.12	0.09	0.07	-	0.10	0.12	0.12
Radiation loss, %	0.90	1.30	5.00	0.90	1.40	2.70	4.50
Unmeasured losses, %	0.50	0.50	0.50	0.50	0.50	0.50	0.50
Total losses, %	23.27	21.70	22.03	18.70	17.60	18.11	18.18
Indirect Efficiency, %	76.73	78.30	77.97	81.30	82.40	81.89	81.82

ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST

PTC 4.1-a(1964)

SUMMARY SHEET

TEST NO. 1	BOILER NO. 2	DATE 14/1/75
OWNER OF PLANT DND	LOCATION CFB Ottawa North	
TEST CONDUCTED BY A.C.S. Hayden, R.G. Fohse	OBJECTIVE OF TEST Acceptance	DURATION 1 hr
BOILER, MAKE & TYPE Foster Wheeler	RATED CAPACITY 31,000 lb/hr	
STOKER, TYPE & SIZE		
PULVERIZER, TYPE & SIZE		BURNER, TYPE & SIZE Todd
FUEL USED Natural Gas MINE	COUNTY	STATE SIZE AS FIRED

PRESSURES & TEMPERATURES				FUEL DATA					
1	STEAM PRESSURE IN BOILER DRUM	psia	146.7	COAL AS FIRED PROX. ANALYSIS		% wt	OIL		
2	STEAM PRESSURE AT S.H. OUTLET HDR	psia	140.7	37	MOISTURE		51	FLASH POINT F*	
3	STEAM PRESSURE AT R. H. INLET	psia		38	VOL MATTER		52	Sp. Gravity Deg. API*	
4	STEAM PRESSURE AT R. H. OUTLET	psia		39	FIXED CARBON		53	VISCOSITY AT SSU* BURNER SSF	
5	STEAM TEMPERATURE AT S. H. OUTLET	F		40	ASH		44	TOTAL HYDROGEN % wt	
6	STEAM TEMPERATURE AT R.H. INLET	F		TOTAL			41	Btu per lb	
7	STEAM TEMPERATURE AT R.H. OUTLET	F		41	Btu per lb AS FIRED				
8	WATER TEMP. ENTERING (ECON.) (BOILER)	F	216	42	ASH SOFT TEMP.* ASTM METHOD			GAS % VOL	
9	STEAM QUALITY % MOISTURE OR P. P. M.			COAL OR OIL AS FIRED ULTIMATE ANALYSIS			54	CO	
10	AIR TEMP. AROUND BOILER (AMBIENT)	F	74	43	CARBON		55	CH ₄ METHANE 93.17	
11	TEMP. AIR FOR COMBUSTION (This is Reference Temperature) †	F	82	44	HYDROGEN		56	C ₂ H ₆ 4.14	
12	TEMPERATURE OF FUEL	F	35	45	OXYGEN		57	C ₃ H ₈ 0.15	
13	GAS TEMP. LEAVING (Boiler) (ECON.) (AIR HTR)	F	607	46	NITROGEN		58	C ₄ H ₁₀ 0.02	
14	GAS TEMP. ENTERING AH (If conditions to be corrected to guarantee)	F		47	SULPHUR		59	Nitrogen 2.21	
UNIT QUANTITIES				40	ASH		60	CO ₂ 0.36	
15	ENTHALPY OF SAT. LIQUID (TOTAL HEAT)	Btu/lb		37	MOISTURE		61		
16	ENTHALPY OF (SATURATED) (SUPERHEATED) STM.	Btu/lb	1193.7	TOTAL			TOTAL 100.0		
17	ENTHALPY OF SAT. FEED TO (BOILER) (ECON.)	Btu/lb	184.1	COAL PULVERIZATION			TOTAL HYDROGEN % wt 23.65		
18	ENTHALPY OF REHEATED STEAM R.H. INLET	Btu/lb		48	GRINDABILITY INDEX*		62	DENSITY 68 F ATM. PRESS. .588	
19	ENTHALPY OF REHEATED STEAM R. H. OUTLET	Btu/lb		49	FINENESS % THRU 50 M*		63	Btu PER CU FT 1006	
20	HEAT ABS/LB OF STEAM (ITEM 16 - ITEM 17)	Btu/lb	1009.6	50	FINENESS % THRU 200 M*		41	Btu PER LB 22438	
21	HEAT ABS/LB R.H. STEAM (ITEM 19 - ITEM 18)	Btu/lb		64	INPUT-OUTPUT EFFICIENCY OF UNIT %	ITEM 31 x 100 / ITEM 29			
22	DRY REFUSE (ASH PIT + FLY ASH) PER LB AS FIRED FUEL	lb/lb		HEAT LOSS EFFICIENCY				Btu/lb A. F. FUEL	% of A. F. FUEL
23	Btu PER LB IN REFUSE (WEIGHTED AVERAGE)	Btu/lb		65	HEAT LOSS DUE TD DRY GAS			2135.70	9.52
24	CARBON BURNED PER LB AS FIRED FUEL	lb/lb	.7203	66	HEAT LOSS DUE TD MOISTURE IN FUEL				
25	DRY GAS PER LB AS FIRED FUEL BURNED	lb/lb	16.95	67	HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂			2743.76	12.23
HOURLY QUANTITIES				68	HEAT LOSS DUE TO CO			27.77	0.12
26	ACTUAL WATER EVAPORATED	lb/hr	29750	69	HEAT LOSS DUE TO RADIATION				0.90
27	REHEAT STEAM FLOW	lb/hr		70	UNMEASURED LOSSES				0.50
28	RATE OF FUEL FIRING (AS FIRED wt)	lb/hr		71	TOTAL				23.27
29	TOTAL HEAT INPUT (Item 28 x Item 41) / 1000	kB/hr		72	EFFICIENCY = (100 - Item 71)				76.73
30	HEAT OUTPUT IN BLOW-DOWN WATER	kB/hr							
31	TOTAL HEAT OUTPUT (Item 26 x Item 20) + (Item 27 x Item 21) + Item 30 / 1000	kB/hr	30040						

FLUE GAS ANAL. (BOILER) (ECON) (AIR HTR) OUTLET			
32	CO ₂	% VOL	10.5
33	O ₂	% VOL	1.93
34	CO	% VOL	.04
35	N ₂ (BY DIFFERENCE)	% VOL	87.57
36	EXCESS AIR	%	8.85

* Not Required for Efficiency Testing

† For Point of Measurement See Par. 7.2.8.1-PTC 4.1-1964

SUMMARY SHEET

ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST

PTC 4.1-a (1964)

TEST NO.	2	BOILER NO.	2	DATE	14/1/75	
OWNER OF PLANT	DND		LOCATION	CFB Ottawa North		
TEST CONDUCTED BY	A.C.S. Hayden, R.G. Fohse		OBJECTIVE OF TEST	Acceptance	DURATION	1 hr
BOILER, MAKE & TYPE	Foster Wheeler		RATED CAPACITY 31,000 lb/hr			
STOKER, TYPE & SIZE						
PULVERIZER, TYPE & SIZE			BURNER, TYPE & SIZE			Todd
FUEL USED	Natural Gas	MINE	COUNTY	STATE	SIZE AS FIRED	

PRESSURES & TEMPERATURES				FUEL DATA					
1	STEAM PRESSURE IN BOILER DRUM	psia	144.7	COAL AS FIRED PROX. ANALYSIS		% wt		OIL	
2	STEAM PRESSURE AT XXXXXXXXXX HDR	psia	138.7	37	MOISTURE		51	FLASH POINT F*	
3	STEAM PRESSURE AT R. H. INLET	psia		38	VOL MATTER		52	Sp. Gravity Deg. API*	
4	STEAM PRESSURE AT R. H. OUTLET	psia		39	FIXED CARBON		53	VISCOSITY AT SSU* BURNER SSF	
5	STEAM TEMPERATURE AT S. H. OUTLET	F		40	ASH		44	TOTAL HYDROGEN % wt	
6	STEAM TEMPERATURE AT R. H. INLET	F		TOTAL			41	Btu per lb	
7	STEAM TEMPERATURE AT R. H. OUTLET	F		41	Btu per lb AS FIRED				
8	WATER TEMP. ENTERING ECON (BOILER)	F	216	42	ASH SOFT TEMP.* ASTM METHOD			GAS	% VOL
9	STEAM QUALITY % MOISTURE OR P. P. M.			COAL OR OIL AS FIRED ULTIMATE ANALYSIS			54	CO	
10	AIR TEMP. AROUND BOILER (AMBIENT)	F	75	43	CARBON		55	CH ₄ METHANE	93.17
11	TEMP. AIR FOR COMBUSTION (This is Reference Temperature) †	F	81	44	HYDROGEN		56	C ₂ H ₆	4.14
12	TEMPERATURE OF FUEL	F	35	45	OXYGEN		57	C ₃ H ₈	0.15
13	GAS TEMP. LEAVING (Boiler) (ECON) (AIR HTR)	F	517	46	NITROGEN		58	C ₂ H ₁₀	0.02
14	GAS TEMP. ENTERING AH (If conditions to be corrected to guarantee)	F		47	SULPHUR		59	N ₂ Nitrogen	2.21
				40	ASH		60	CO ₂	0.36

UNIT QUANTITIES				HEAT LOSS EFFICIENCY					
15	ENTHALPY OF SAT. LIQUID (TOTAL HEAT)	Btu/lb		37	MOISTURE		61	H ₂ HYDROGEN	
16	ENTHALPY OF (SATURATED) (SUPERHEATED) STM.	Btu/lb	1193.5	TOTAL			TOTAL		100.0
17	ENTHALPY OF SAT. FEED TO (BOILER) (ECON)	Btu/lb	184.1	COAL PULVERIZATION			TOTAL HYDROGEN % wt		23.65
18	ENTHALPY OF REHEATED STEAM R. H. INLET	Btu/lb		48	GRINDABILITY INDEX*		62	DENSITY 68 F ATM. PRESS.	5.88
19	ENTHALPY OF REHEATED STEAM R. H. OUTLET	Btu/lb		49	FINENESS % THRU 50 M*		63	Btu PER CU FT	1006
20	HEAT ABS/LB OF STEAM (ITEM 16 - ITEM 17)	Btu/lb	1009.4	50	FINENESS % THRU 200 M*		41	Btu PER LB	22438
21	HEAT ABS/LB R. H. STEAM (ITEM 19 - ITEM 18)	Btu/lb		64	INPUT-OUTPUT EFFICIENCY OF UNIT %		ITEM 31 x 100 ITEM 29		
22	DRY REFUSE (ASH PIT + FLY ASH) PER LB AS FIRED FUEL	lb/lb		HEAT LOSS EFFICIENCY			Btu/lb A. F. FUEL	% of A. F. FUEL	
23	Btu PER LB IN REFUSE (WEIGHTED AVERAGE)	Btu/lb		65	HEAT LOSS DUE TO DRY GAS		1790.39	7.98	
24	CARBON BURNED PER LB AS FIRED FUEL	lb/lb	.7203	66	HEAT LOSS DUE TO MOISTURE IN FUEL				
25	DRY GAS PER LB AS FIRED FUEL BURNED	lb/lb	17.11	67	HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂		2654.96	11.83	
				68	HEAT LOSS DUE TO CO		21.05	0.09	

HOURLY QUANTITIES				EFFICIENCY				
26	ACTUAL WATER EVAPORATED	lb/hr	20700	69	HEAT LOSS DUE TO RADIATION			1.30
27	REHEAT STEAM FLOW	lb/hr		70	UNMEASURED LOSSES			0.50
28	RATE OF FUEL FIRING (AS FIRED wt)	lb/hr		71	TOTAL			21.70
29	TOTAL HEAT INPUT (Item 28 x Item 41) 1000	kB/hr		72	EFFICIENCY = (100 - Item 71)			78.30
30	HEAT OUTPUT IN BLOW-DOWN WATER	kB/hr						
31	TOTAL HEAT OUTPUT (Item 26 x Item 20) + (Item 27 x Item 21) + Item 30 1000	kB/hr	20890					

FLUE GAS ANAL. (BOILER) (ECON) (AIR HTR) OUTLET			
32	CO ₂	% VOL	10.4
33	O ₂	% VOL	1.93
34	CO	% VOL	.03
35	N ₂ (BY DIFFERENCE)	% VOL	87.64
36	EXCESS AIR	%	8.87

* Not Required for Efficiency Testing

† For Point of Measurement See Par. 7.2.8.1-PTC 4.1-1964

**ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST**

SUMMARY SHEET

TEST NO.	3	BOILER NO.	2	DATE	14/1/75	
OWNER OF PLANT	DND		LOCATION	CFB Ottawa North		
TEST CONDUCTED BY	A.C.S. Hayden, R.G. Fouchse		OBJECTIVE OF TEST	Acceptance	DURATION	1 hr
BOILER, MAKE & TYPE	Foster Wheeler		RATED CAPACITY	31,000 lb/hr		
STOKER, TYPE & SIZE						
PULVERIZER, TYPE & SIZE			BURNER, TYPE & SIZE			Todd
FUEL USED	Natural Gas	MINE	COUNTY	STATE	SIZE AS FIRED	

PRESSURES & TEMPERATURES				FUEL DATA					
1	STEAM PRESSURE IN BOILER DRUM	psia	139.7	COAL AS FIRED PROX. ANALYSIS		% wt		OIL	
2	STEAM PRESSURE AT S. H. OUTLET HDR	psia	134.7	37	MOISTURE		51	FLASH POINT F*	
3	STEAM PRESSURE AT R. H. INLET	psia		38	VOL MATTER		52	Sp. Gravity	
4	STEAM PRESSURE AT R. H. OUTLET	psia		39	FIXED CARBON		53	VISCOSITY AT SSU* BURNER SSF	
5	STEAM TEMPERATURE AT S. H. OUTLET	F		40	ASH		44	TOTAL HYDROGEN % wt	
6	STEAM TEMPERATURE AT R.H. INLET	F		TOTAL			41	Btu per lb	
7	STEAM TEMPERATURE AT R.H. OUTLET	F		41	Btu per lb AS FIRED				
8	WATER TEMP. ENTERING (ECON.) (BOILER)	F	217	42	ASH SOFT TEMP.* ASTM METHOD			GAS	% VOL
9	STEAM QUALITY % MOISTURE OR P. P. M.			COAL OR OIL AS FIRED ULTIMATE ANALYSIS			54	CO	
10	AIR TEMP. AROUND BOILER (AMBIENT)	F	75	43	CARBON		55	CH ₄ METHANE	93.17
11	TEMP. AIR FOR COMBUSTION (This is Reference Temperature) †	F	81	44	HYDROGEN		56	C ₂ H ₆	4.14
12	TEMPERATURE OF FUEL	F	35	45	OXYGEN		57	C ₃ H ₈	0.15
13	GAS TEMP. LEAVING (Boiler) (ECON.) (HTR)	F	353	46	NITROGEN		58	C ₄ H ₁₀	0.02
14	GAS TEMP. ENTERING AH (If conditions to be corrected to guarantee)	F		47	SULPHUR		59	N ₂ Nitrogen	2.21
				40	ASH		60	CO ₂	0.36

UNIT QUANTITIES				HEAT LOSS EFFICIENCY					
15	ENTHALPY OF SAT. LIQUID (TOTAL HEAT)	Btu/lb		37	MOISTURE		61	H ₂ HYDROGEN	
16	ENTHALPY OF (SATURATED) (SUPERHEATED) STM.	Btu/lb	1193.0	TOTAL			TOTAL		100.00
17	ENTHALPY OF SAT. FEED TO (BOILER) (ECON.)	Btu/lb	185.1	COAL PULVERIZATION			TOTAL HYDROGEN % wt		23.65
18	ENTHALPY OF REHEATED STEAM R.H. INLET	Btu/lb		48	GRINDABILITY INDEX*		62	DENSITY 68 F ATM. PRESS.	.588
19	ENTHALPY OF REHEATED STEAM R. H. OUTLET	Btu/lb		49	FINENESS % THRU 50 M*		63	Btu PER CU FT	1006
20	HEAT ABS/LB OF STEAM (ITEM 16 - ITEM 17)	Btu/lb	1007.9	50	FINENESS % THRU 200 M*		41	Btu PER LB	
21	HEAT ABS/LB R.H. STEAM (ITEM 19 - ITEM 18)	Btu/lb		64	INPUT-OUTPUT EFFICIENCY OF UNIT %		ITEM 31 x 100 ITEM 29		
22	DRY REFUSE (ASH PIT + FLY ASH) PER LB AS FIRED FUEL	lb/lb		HEAT LOSS EFFICIENCY			Btu/lb A. F. FUEL	% of A. F. FUEL	
23	Btu PER LB IN REFUSE (WEIGHTED AVERAGE)	Btu/lb		65	HEAT LOSS DUE TO DRY GAS		1197.24	5.35	
24	CARBON BURNED PER LB AS FIRED FUEL	lb/lb	.7203	66	HEAT LOSS DUE TO MOISTURE IN FUEL				
25	DRY GAS PER LB AS FIRED FUEL BURNED	lb/lb	18.34	67	HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂		2492.60	11.11	
HOURLY QUANTITIES				68	HEAT LOSS DUE TO CO		15.06	0.07	
26	ACTUAL WATER EVAPORATED	lb/hr	5000	69	HEAT LOSS DUE TO RADIATION			5.00	
27	REHEAT STEAM FLOW	lb/hr		70	UNMEASURED LOSSES			0.50	
28	RATE OF FUEL FIRING (AS FIRED wt)	lb/hr		71	TOTAL			22.03	
29	TOTAL HEAT INPUT (Item 28 x Item 41) 1000	kB/hr		72	EFFICIENCY = (100 - Item 71)			77.97	
30	HEAT OUTPUT IN BLOW-DOWN WATER	kB/hr							
31	TOTAL HEAT OUTPUT (Item 26 x Item 20) + (Item 27 x Item 21) + Item 30 1000	kB/hr	5040						

FLUE GAS ANAL. (BOILER) (ECON) (AIR HTR) OUTLET			
32	CO ₂	% VOL	9.7
33	O ₂	% VOL	3.6
34	CO	% VOL	.02
35	N ₂ (BY DIFFERENCE)	% VOL	86.68
36	EXCESS AIR	%	18.26

* Not Required for Efficiency Testing

† For Point of Measurement See Par. 7.2.8.1-PTC 4.1-1964

SUMMARY SHEET

ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST

PTC 4.1-a(1964)

TEST NO. 4	BOILER NO. 2	DATE 15/1/75
OWNER OF PLANT DND	LOCATION CFB Ottawa North	
TEST CONDUCTED BY A.C.S. Hayden, R.G. Fohse	OBJECTIVE OF TEST Acceptance	DURATION 1 hr
BOILER, MAKE & TYPE Foster Wheeler	RATED CAPACITY 31,000 lb/hr	
STOKER, TYPE & SIZE		
PULVERIZER, TYPE & SIZE		BURNER, TYPE & SIZE Todd
FUEL USED No. 4 fuel oil MINE	COUNTY	STATE SIZE AS FIRED

PRESSURES & TEMPERATURES

FUEL DATA

		psia		COAL AS FIRED PROX. ANALYSIS	% wt		OIL	
1	STEAM PRESSURE IN BOILER DRUM		140.7					
2	STEAM PRESSURE AT R.H. INLET HDR	psia	134.7	37	MOISTURE	51	FLASH POINT F*	
3	STEAM PRESSURE AT R. H. INLET	psia		38	VOL MATTER	52	Sp. Gravity 0.898	
4	STEAM PRESSURE AT R. H. OUTLET	psia		39	FIXED CARBON	53	VISCOSITY AT SSU* BURNER SSF	
5	STEAM TEMPERATURE AT S. H. OUTLET	F		40	ASH	44	TOTAL HYDROGEN % wt 12.32	
6	STEAM TEMPERATURE AT R. H. INLET	F		TOTAL		41	Btu per lb 20432	
7	STEAM TEMPERATURE AT R. H. OUTLET	F		41	Btu per lb AS FIRED			
8	WATER TEMP. ENTERING (330K) (BOILER)	F	217	42	ASH SOFT TEMP.* ASTM METHOD		GAS % VOL	
9	STEAM QUALITY % MOISTURE OR P. P. M.			COAL OR OIL AS FIRED ULTIMATE ANALYSIS		54	CO	
10	AIR TEMP. AROUND BOILER (AMBIENT)	F	72	43	CARBON	86.37	CH ₄ METHANE	
11	TEMP. AIR FOR COMBUSTION (This is Reference Temperature) †	F	82	44	HYDROGEN	12.36		
12	TEMPERATURE OF FUEL	F	106	45	OXYGEN	-		
13	GAS TEMP. LEAVING (Boiler) (630K)	F	633	46	NITROGEN	0.11		
14	GAS TEMP. ENTERING AH (If conditions to be corrected to guarantee)	F		47	SULPHUR	1.14		
				40	ASH	0.02	60	CO ₂

UNIT QUANTITIES

15	ENTHALPY OF SAT. LIQUID (TOTAL HEAT)	Btu/lb		37	MOISTURE	-	61	H ₂ HYDROGEN
16	ENTHALPY OF (SATURATED) (SUPERHEATED) STM.	Btu/lb	1193.1	TOTAL		100.0	TOTAL	
17	ENTHALPY OF SAT. FEED TO (BOILER) (800K)	Btu/lb	185.1	COAL PULVERIZATION			TOTAL HYDROGEN % wt	
18	ENTHALPY OF REHEATED STEAM R. H. INLET	Btu/lb		48	GRINDABILITY INDEX*		62	DENSITY 68 F ATM. PRESS.
19	ENTHALPY OF REHEATED STEAM R. H. OUTLET	Btu/lb		49	FINENESS % THRU 50 M*		63	Btu PER CU FT
20	HEAT ABS/LB OF STEAM (ITEM 16 - ITEM 17)	Btu/lb	1008.0	50	FINENESS % THRU 200 M*		41	Btu PER LB
21	HEAT ABS/LB R. H. STEAM (ITEM 19 - ITEM 18)	Btu/lb		64	INPUT-OUTPUT EFFICIENCY OF UNIT %	ITEM 31 x 100 ITEM 29 67.86		
22	DRY REFUSE (ASH PIT + FLY ASH) PER LB AS FIRED FUEL	lb/lb		HEAT LOSS EFFICIENCY			Btu/lb A. F. FUEL	% of A. F. FUEL
23	Btu PER LB IN REFUSE (WEIGHTED AVERAGE)	Btu/lb		65	HEAT LOSS DUE TO DRY GAS	2086.75	10.21	
24	CARBON BURNED PER LB AS FIRED FUEL	lb/lb	.8637	66	HEAT LOSS DUE TO MOISTURE IN FUEL			
25	DRY GAS PER LB AS FIRED FUEL BURNED	lb/lb	15.78	67	HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂	1447.86	7.09	
				68	HEAT LOSS DUE TO CO	-	-	

HOURLY QUANTITIES

26	ACTUAL WATER EVAPORATED	lb/hr	29600	69	HEAT LOSS DUE TO RADIATION		0.90
27	REHEAT STEAM FLOW	lb/hr		70	UNMEASURED LOSSES		0.50
28	RATE OF FUEL FIRING (AS FIRED wt)	lb/hr	2152	71	TOTAL		18.70
29	TOTAL HEAT INPUT ($\frac{\text{Item 28} \times \text{Item 41}}{1000}$)	kB/hr	43970	72	EFFICIENCY = (100 - Item 71)		81.30
30	HEAT OUTPUT IN BLOW-DOWN WATER	kB/hr					
31	TOTAL HEAT OUTPUT ($\frac{(\text{Item 26} \times \text{Item 20}) + (\text{Item 27} \times \text{Item 21}) + \text{Item 30}}{1000}$)	kB/hr	29837				

FLUE GAS ANAL. (BOILER) (ECON) (AIR HTR) OUTLET

32	CO ₂	% VOL	13.9
33	O ₂	% VOL	2.51
34	CO	% VOL	-
35	N ₂ (BY DIFFERENCE)	% VOL	83.59
36	EXCESS AIR	%	12.61

* Not Required for Efficiency Testing

† For Point of Measurement See Par. 7.2.8.1-PTC 4.1-1964

ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST

PTC 4.1-a(1964)

SUMMARY SHEET

TEST NO. 5	BOILER NO. 2	DATE 15/1/75
OWNER OF PLANT DND.	LOCATION CFB Ottawa North	
TEST CONDUCTED BY A.C.S. Hayden, R.G. Fohse	OBJECTIVE OF TEST Acceptance	DURATION 1 hr
BOILER, MAKE & TYPE Foster Wheeler		RATED CAPACITY 31,000 lb/hr
STOKER, TYPE & SIZE		
PULVERIZER, TYPE & SIZE		
BURNER, TYPE & SIZE Todd		
FUEL USED No. 4 fuel oil MINE	COUNTY	STATE SIZE AS FIRED

PRESSURES & TEMPERATURES				FUEL DATA					
1	STEAM PRESSURE IN BOILER DRUM	psia	138.7	COAL AS FIRED PROX. ANALYSIS		% wt		OIL	
2	STEAM PRESSURE AT XXXXXX HDR	psia	132.7	37	MOISTURE		51	FLASH POINT F*	
3	STEAM PRESSURE AT R. H. INLET	psia		38	VOL MATTER		52	Sp. Gravity	0.898
4	STEAM PRESSURE AT R. H. OUTLET	psia		39	FIXED CARBON		53	VISCOSITY AT SSU* BURNER SSF	
5	STEAM TEMPERATURE AT S. H. OUTLET	F		40	ASH		44	TOTAL HYDROGEN % wt	12.32
6	STEAM TEMPERATURE AT R. H. INLET	F		TOTAL			41	Btu per lb	20432
7	STEAM TEMPERATURE AT R. H. OUTLET	F		41	Btu per lb AS FIRED				
8	WATER TEMP. ENTERING (ECON) (BOILER)	F	202	42	ASH SOFT. TEMP.* ASTM METHOD			GAS % VOL	
9	STEAM QUALITY % MOISTURE OR P. P. M.			COAL OR OIL AS FIRED ULTIMATE ANALYSIS			54	CO	
10	AIR TEMP. AROUND BOILER (AMBIENT)	F	74	43	CARBON	86.37	55	CH ₄ METHANE	
11	TEMP. AIR FOR COMBUSTION (This is Reference Temperature) †	F	81	44	HYDROGEN	12.36	56		
12	TEMPERATURE OF FUEL	F	106	45	OXYGEN	-	57		
13	GAS TEMP. LEAVING (Boiler) XXXXXX	F	535	46	NITROGEN	0.11	58		
14	GAS TEMP. ENTERING AH (If conditions to be corrected to guarantee)	F		47	SULPHUR	1.14	59		
				40	ASH	0.02	60	CO ₂	

UNIT QUANTITIES									
15	ENTHALPY OF SAT. LIQUID (TOTAL HEAT)	Btu/lb		37	MOISTURE		61	H ₂ HYDROGEN	
16	ENTHALPY OF (SATURATED) (XXXXXX) STM.	Btu/lb	1192.9	TOTAL		100.0	TOTAL		
17	ENTHALPY OF SAT. FEED TO (BOILER) (XXXX)	Btu/lb	170.0	COAL PULVERIZATION			TOTAL HYDROGEN % wt		
18	ENTHALPY OF REHEATED STEAM R. H. INLET	Btu/lb		48	GRINDABILITY INDEX*		62	DENSITY 68 F ATM. PRESS.	
19	ENTHALPY OF REHEATED STEAM R. H. OUTLET	Btu/lb		49	FINENESS % THRU 50 M*		63	Btu PER CU FT	
20	HEAT ABS/LB OF STEAM (ITEM 16 - ITEM 17)	Btu/lb	1022.9	50	FINENESS % THRU 200 M*		41	Btu PER LB	
21	HEAT ABS/LB R. H. STEAM (ITEM 19 - ITEM 18)	Btu/lb		64	INPUT-OUTPUT EFFICIENCY OF UNIT %		ITEM 31 x 100 ITEM 29 66.39		
22	DRY REFUSE (ASH PIT + FLY ASH) PER LB AS FIRED FUEL	lb/lb		HEAT LOSS EFFICIENCY			Btu/lb A. F. FUEL	% of A. F. FUEL	
23	Btu PER LB IN REFUSE (WEIGHTED AVERAGE)	Btu/lb		65	HEAT LOSS DUE TO DRY GAS		1789.12	8.76	
24	CARBON BURNED PER LB AS FIRED FUEL	lb/lb	.8637	66	HEAT LOSS DUE TO MOISTURE IN FUEL				
25	DRY GAS PER LB AS FIRED FUEL BURNED	lb/lb	16.42	67	HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂		1397.03	6.84	
				68	HEAT LOSS DUE TO CO		19.75	0.10	

HOURLY QUANTITIES									
26	ACTUAL WATER EVAPORATED	lb/hr	19010	69	HEAT LOSS DUE TO RADIATION			1.40	
27	REHEAT STEAM FLOW	lb/hr		70	UNMEASURED LOSSES			0.50	
28	RATE OF FUEL FIRING (AS FIRED wt)	lb/hr	1434	71	TOTAL			17.60	
29	TOTAL HEAT INPUT (Item 28 x Item 41) 1000	kB/hr	29290	72	EFFICIENCY = (100 - Item 71)			82.40	
30	HEAT OUTPUT IN BLOW-DOWN WATER	kB/hr							
31	TOTAL HEAT OUTPUT (Item 26 x Item 20) + (Item 27 x Item 21) + Item 30 1000	kB/hr	19445						

FLUE GAS ANAL. (BOILER) (ECON) (AIR HTR) OUTLET			
32	CO ₂	% VOL	13.3
33	O ₂	% VOL	3.50
34	CO	% VOL	.03
35	N ₂ (BY DIFFERENCE)	% VOL	83.17
36	EXCESS AIR	%	18.52

* Not Required for Efficiency Testing

† For Point of Measurement See Par. 7.2.8.1-PTC 4.1-1964

ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST

PTC 4.1-a(1964)

SUMMARY SHEET

TEST NO. 6	BOILER NO. 2	DATE 15/1/75
OWNER OF PLANT DND	LOCATION CFB Ottawa North	
TEST CONDUCTED BY A.C.S. Hayden, R.G. Fohse	OBJECTIVE OF TEST Acceptance	DURATION .5 hr
BOILER, MAKE & TYPE Foster Wheeler	RATED CAPACITY 31,000 lb/hr	
STOKER, TYPE & SIZE		
PULVERIZER, TYPE & SIZE		BURNER, TYPE & SIZE Todd
FUEL USED No. 4 fuel oil MINE	COUNTY	STATE SIZE AS FIRED

PRESSURES & TEMPERATURES

FUEL DATA

1	STEAM PRESSURE IN BOILER DRUM	psia	135.7	COAL AS FIRED PROX. ANALYSIS		% wt	OIL	
2	STEAM PRESSURE AT R.H. INLET	psia	129.7	37	MOISTURE		51	FLASH POINT F*
3	STEAM PRESSURE AT R. H. INLET	psia		38	VOL. MATTER		52	Sp. Gravity 0.998
4	STEAM PRESSURE AT R. H. OUTLET	psia		39	FIXED CARBON		53	VISCOSITY AT SSU* BURNER SSF
5	STEAM TEMPERATURE AT S. H. OUTLET	F		40	ASH		44	TOTAL HYDROGEN % wt 12.36
6	STEAM TEMPERATURE AT R. H. INLET	F		TOTAL			41	Btu per lb 20432
7	STEAM TEMPERATURE AT R. H. OUTLET	F		41	Btu per lb AS FIRED			
8	WATER TEMP. ENTERING (800K) (BOILER)	F	204	42	ASH SOFT TEMP.* ASTM METHOD		GAS % VOL	
9	STEAM QUALITY % MOISTURE OR P. P. M.			COAL OR OIL AS FIRED ULTIMATE ANALYSIS			54	CO
10	AIR TEMP. AROUND BOILER (AMBIENT)	F	75	43	CARBON	86.37	55	CH ₄ METHANE
11	TEMP. AIR FOR COMBUSTION (This is Reference Temperature) †	F	80	44	HYDROGEN	12.36	56	C ₂ H ₂ ACETYLENE
12	TEMPERATURE OF FUEL	F	106	45	OXYGEN	-	57	C ₂ H ₄ ETHYLENE
13	GAS TEMP. LEAVING (Boiler) (860K) (860K)	F	435	46	NITROGEN	0.11	58	C ₂ H ₆ ETHANE
14	GAS TEMP. ENTERING AH (If conditions to be corrected to guarantee)	F		47	SULPHUR	1.14	59	H ₂ S
				40	ASH	0.02	60	CO ₂

UNIT QUANTITIES

15	ENTHALPY OF SAT. LIQUID (TOTAL HEAT)	Btu/lb		37	MOISTURE	-	61	H ₂ HYDROGEN
16	ENTHALPY OF (SATURATED) (SUPERHEATED) STM.	Btu/lb	1192.5	TOTAL		100.0	TOTAL	
17	ENTHALPY OF SAT. FEED TO (BOILER) (800K)	Btu/lb	172.0	COAL PULVERIZATION			TOTAL HYDROGEN % wt	
18	ENTHALPY OF REHEATED STEAM R. H. INLET	Btu/lb		48	GRINDABILITY INDEX*		62	DENSITY 68 F ATM. PRESS.
19	ENTHALPY OF REHEATED STEAM R. H. OUTLET	Btu/lb		49	FINENESS % THRU 50 M*		63	Btu PER CU FT
20	HEAT ABS/LB OF STEAM (ITEM 16 - ITEM 17)	Btu/lb	1020.5	50	FINENESS % THRU 200 M*		41	Btu PER LB
21	HEAT ABS/LB R. H. STEAM (ITEM 19 - ITEM 18)	Btu/lb		64	INPUT-OUTPUT EFFICIENCY OF UNIT %	ITEM 31 x 100 ITEM 29		66.55
22	DRY REFUSE (ASH PIT + FLY ASH) PER LB AS FIRED FUEL	lb/lb		HEAT LOSS EFFICIENCY			Btu/lb A. F. FUEL	% of A. F. FUEL
23	Btu PER LB IN REFUSE (WEIGHTED AVERAGE)	Btu/lb		65	HEAT LOSS DUE TO DRY GAS		1675.88	8.20
24	CARBON BURNED PER LB AS FIRED FUEL	lb/lb	.8637	66	HEAT LOSS DUE TO MOISTURE IN FUEL			
25	DRY GAS PER LB AS FIRED FUEL BURNED	lb/lb	19.67	67	HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂		1345.96	6.59

HOURLY QUANTITIES

26	ACTUAL WATER EVAPORATED	lb/hr	9700	68	HEAT LOSS DUE TO CO		23.87	0.12
27	REHEAT STEAM FLOW	lb/hr.		69	HEAT LOSS DUE TO RADIATION			2.70
28	RATE OF FUEL FIRING (AS FIRED wt)	lb/hr	728	70	UNMEASURED LOSSES			0.50
29	TOTAL HEAT INPUT (Item 28 x Item 41) 1000	kB/hr	14874	71	TOTAL			18.11
30	HEAT OUTPUT IN BLOW-DOWN WATER	kB/hr		72	EFFICIENCY = (100 - Item 71)			81.89
31	TOTAL HEAT OUTPUT (Item 26 x Item 20) + (Item 27 x Item 21) + Item 30 1000	kB/hr	9899					

FLUE GAS ANAL. (BOILER) (ECON) (AIR HTR) OUTLET

32	CO ₂	% VOL	11.0
33	O ₂	% VOL	6.0
34	CO	% VOL	0.03
35	N ₂ (BY DIFFERENCE)	% VOL	82.97
36	EXCESS AIR	%	36.79

* Not Required for Efficiency Testing

† For Point of Measurement See Par. 7.2.8.1-PTC 4.1-1964

**TABLE 11
ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST**

SUMMARY SHEET

PTC 4.1-a(1964)

TEST NO. 7	BOILER NO. 2	DATE 15/1/75
OWNER OF PLANT DND	LOCATION CFB Ottawa North	
TEST CONDUCTED BY A.C.S. Hayden, R.G. Fohse.	OBJECTIVE OF TEST Acceptance	DURATION .25hr
BOILER, MAKE & TYPE Foster Wheeler	RATED CAPACITY 31,000 lb/hr	
STOKER, TYPE & SIZE		
PULVERIZER, TYPE & SIZE	BURNER, TYPE & SIZE Todd	
FUEL USED No. 4 fuel oil MINE	COUNTY	STATE
SIZE AS FIRED		

PRESSURES & TEMPERATURES				FUEL DATA				
1	STEAM PRESSURE IN BOILER DRUM	psia	135.7	COAL AS FIRED PROX. ANALYSIS		% wt	OIL	
2	STEAM PRESSURE AT ENHANCED HDR	psia	129.7	37	MOISTURE		51	FLASH POINT F*
3	STEAM PRESSURE AT R. H. INLET	psia		38	VOL MATTER		52	Sp. Gravity
4	STEAM PRESSURE AT R. H. OUTLET	psia		39	FIXED CARBON		53	VISCOSITY AT SSU* BURNER SSF
5	STEAM TEMPERATURE AT S. H. OUTLET	F		40	ASH		44	TOTAL HYDROGEN % wt
6	STEAM TEMPERATURE AT R.H. INLET	F		TOTAL			41	Btu per lb
7	STEAM TEMPERATURE AT R.H. OUTLET	F		41	Btu per lb AS FIRED			
8	WATER TEMP. ENTERING (ECON) (BOILER)	F	212	42	ASH SOFT TEMP.* ASTM METHOD			GAS % VOL
9	STEAM QUALITY % MOISTURE OR P. P. M.			COAL OR OIL AS FIRED ULTIMATE ANALYSIS			54	CO
10	AIR TEMP. AROUND BOILER (AMBIENT)	F	75	43	CARBON	86.37	55	CH ₄ METHANE
11	TEMP. AIR FOR COMBUSTION (This is Reference Temperature) †	F	80	44	HYDROGEN	12.36	56	C ₂ H ₂ ACETYLENE
12	TEMPERATURE OF FUEL	F	106	45	OXYGEN		57	C ₂ H ₄ ETHYLENE
13	GAS TEMP. LEAVING (Boiler) (ECON) (AIR HTR)	F	370	46	NITROGEN	0.11	58	C ₂ H ₆ ETHANE
14	GAS TEMP. ENTERING AH (If conditions to be corrected to guarantee)	F		47	SULPHUR	1.14	59	H ₂ S
				40	ASH	0.02	60	CO ₂

UNIT QUANTITIES				HEAT LOSS EFFICIENCY				
15	ENTHALPY OF SAT. LIQUID (TOTAL HEAT)	Btu/lb		37	MOISTURE	-	61	H ₂ HYDROGEN
16	ENTHALPY OF (SATURATED) (SUPERHEATED) STM.	Btu/lb	11925	TOTAL		100.0	TOTAL	
17	ENTHALPY OF SAT. FEED TO (BOILER) (ECON)	Btu/lb	180.1	COAL PULVERIZATION			TOTAL HYDROGEN % wt	
18	ENTHALPY OF REHEATED STEAM R. H. INLET	Btu/lb		48	GRINDABILITY INDEX*		62	DENSITY 68 F ATM. PRESS.
19	ENTHALPY OF REHEATED STEAM R. H. OUTLET	Btu/lb		49	FINENESS % THRU 50 M*		63	Btu PER CU FT
20	HEAT ABS/LB OF STEAM (ITEM 16 - ITEM 17)	Btu/lb	1012.4	50	FINENESS % THRU 200 M*		41	Btu PER LB
21	HEAT ABS/LB R. H. STEAM (ITEM 19 - ITEM 18)	Btu/lb		64	INPUT-OUTPUT EFFICIENCY OF UNIT %		ITEM 31 x 100 ITEM 29 71.97	
22	DRY REFUSE (ASH PIT + FLY ASH) PER LB AS FIRED FUEL	lb/lb		HEAT LOSS EFFICIENCY			Btu/lb A. F. FUEL	% of A. F. FUEL
23	Btu PER LB IN REFUSE (WEIGHTED AVERAGE)	Btu/lb		65	HEAT LOSS DUE TO DRY GAS		1357.20	6.64
24	CARBON BURNED PER LB AS FIRED FUEL	lb/lb	.8637	66	HEAT LOSS DUE TO MOISTURE IN FUEL			
25	DRY GAS PER LB AS FIRED FUEL BURNED	lb/lb	19.50	67	HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂		1312.50	6.42
				68	HEAT LOSS DUE TO CO		23.65	0.12
26	ACTUAL WATER EVAPORATED	lb/hr	5680	69	HEAT LOSS DUE TO RADIATION			4.50
27	REHEAT STEAM FLOW	lb/hr		70	UNMEASURED LOSSES			0.50
28	RATE OF FUEL FIRING (AS FIRED wt)	lb/hr	391	71	TOTAL			18.18
29	TOTAL HEAT INPUT (Item 28 x Item 41) 1000	kB/hr	7989	72	EFFICIENCY = (100 - Item 71)			81.82
30	HEAT OUTPUT IN BLOW-DOWN WATER	kB/hr						
31	TOTAL HEAT OUTPUT (Item 26 x Item 20) + (Item 27 x Item 21) + Item 30 1000	kB/hr	5750					

FLUE GAS ANAL. (BOILER) (ECON) (AIR HTR) OUTLET			
32	CO ₂	% VOL	11.1
33	O ₂	% VOL	5.8
34	CO	% VOL	.03
35	N ₂ (BY DIFFERENCE)	% VOL	83.07
36	EXCESS AIR	%	35.07

* Not Required for Efficiency Testing

† For Point of Measurement See Par. 7.2.8.1-PTC 4.1-1964

APPENDIX A

BOILER AND BURNER SPECIFICATIONS

1. Boilers:

- No. 1: Inglis, Type VL, 400 HP
- No. 2: Foster Wheeler, 31,000 lb/hr
- No. 3 & No. 4: Waterous, 31,000 lb/hr

2. Burners:

- No. 1: 2 parallel Compower oil/gas burners
- No. 2: Todd D18, Number 197354
 - Input Btu: min 5.5 MM, max 31 MM
 - Natural gas and No. 4 oil
 - Inlet gas: 10 psig Steam atomized oil burner
 - Manifold gas: 3 psig Oil pressure: 100 psig
 - Max gas I/P: 8750 CFM Max oil I/P: 2100 lb/hr
- No. 3 & No. 4: Single Compower oil/gas burner